



POWER PROJECT DATA

A) POWER GAS TURBINE NO 1 DATA

1. Equipment Model :- MS 9001E
 2. Equipment Serial No:-
 3. Turbine Rating : 123MW
 4. Year of Manufacturing :1993
 5. Year of Starting Operation: 1994
 6. Last Hot Gas Path Major Inspection: 8th Dec 2015 – 31st Dec 2015
-

OPERATIONAL DATA OF GT NO 1

Total Fired Hours: 174,357
Total Fired Starts: 2010
Total Emergency Stops: 199
Peak Fired Hours: 0
Total Starts:2209

B) POWER GAS TURBINE NO 2 DATA

1. Equipment Model :- MS 9001E
 2. Equipment Serial No:-
 3. Turbine Rating : 123MW
 4. Year of Manufacturing :1994
 5. Year of Starting Operation: 1994
 6. Last Hot Gas Path Major Inspection: 8th Dec 2015 – 2nd Jan 2016
-

OPERATIONAL DATA OF GT NO 2

Total Fired Hours: 173,221
Total Fired Starts: 1513
Total Emergency Stops: 189
Peak Fired Hours: 0
Total Starts: 1702